

Commissioning report for the system operator

Südwind vacuum monitor

Installation date: _____

Serial number: E0100 _____

Heat-producing appliance: _____

Manufacturer: _____

Type: _____

System operator: _____

Street / house number: _____

Postcode / city: _____

Phone / mobile: _____

Type of heat-producing appliance: _____

Parameters of the vacuum monitor:

Differential pressure threshold: 4 Pa

Alarm delay: 150 seconds

waiting time for manual unlocking: 3x alarm delay

Important notes:

The operator must inform the authorised district chimney sweep about the installation and commissioning. On request, the parameters must be submitted to the authorised district chimney sweep.

The technical documentation and the commissioning report must be kept by the operator.

System operator

The technical documentation was handed over to the operator.
They were familiarised with the safety instructions, the operation
and maintenance of the above mentioned system.

Installation company / stamp

Date and signature

Date and signature